



Prince William County

PUBLIC SCHOOLS

Providing A World-Class Education

ADDENDUM

ADDENDUM # 4

DATE: April 30, 2009

REFERENCE: Invitation for Bid: S-BB-9607
IFB Issue Date: April 8, 2009
Title & Location: Godwin Middle School Renewal,
State Project #75-64E,
14800 Darbydale Ave., Woodbridge, VA 22193
Architect/Engineer: Architecture, Inc.
Sealed Bid Due Date: May 7, 2009 @ 3:00 p.m.

THE FOLLOWING CHANGES, ADDITIONS, DELETIONS AND CLARIFICATIONS ARE HEREBY MADE PART OF THE BIDDING REQUIREMENTS AND CONTRACT DOCUMENTS FOR THE ABOVE REFERENCED PROJECT AND SHALL BE TAKEN INTO ACCOUNT IN THE PREPARATION OF ALL BIDS AND THE EXECUTION OF ALL WORK. BIDDERS SHALL ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE APPROPRIATE SPACE ON THE BID FORM.

- A. Specifications:
1. Section 08212: Delete in its entirety.
- B. Drawings:
1. Sheet E4.2: Add an IDF in Janitor's Closet 719. Provide a duplex power outlet mounted on the IDF rack. Connect the duplex outlet to a dedicated circuit to emergency panel in Main Office. Provide phone and data cables from MDF to IDF per specifications.
 2. Sheet E4.4 Add an IDF in Janitor's Closet 516. Provide a duplex power outlet mounted on the IDF rack. Connect the duplex outlet to a dedicated circuit to emergency panel in Main Office. Provide phone and data cables from MDF to IDF per specifications.
- C. Clarifications:
1. Existing plumbing piping protruding out of the wall in 6th Grade 108 shall be capped in the wall cavity and the cmu face which has the penetration shall be replaced.
 2. Existing chalk and tack boards shall be removed by the Owner's Abatement Contractor. Existing tack strips shall be removed by the General Contractor.
 3. Cost Item #1 is to not build the addition on the front of the building. In place, the south east corner of the existing Cafeteria will be renewed like the rest of the room and Entry (937) will not be constructed. The lighting pattern for the Cafeteria will continue into the corner. The exit light

PWCPS BID # S-BB-9607

PURCHASING DEPARTMENT

will be placed over the existing door (901).

D. Alternate Manufacturer's:

1. Light fixtures:

<u>Type</u>	<u>Factory</u>	<u>Description</u>
E.	Lumark	LC42C-PB277
F	Lumark	MPMN-150-MT-PE/WA1XX (277V adapter)
X1	Sure-Lites	CX61R
X2	Sure-Lites	CX61R
X3	Sure-Lites	CX62R

2. Fuller & d'Albert, Inc., PO Box 2706, Fairfax, VA 22031, (703) 591-8000 is an acceptable manufacturer of Plastic Laminate Casework.

3. Light fixtures:

<u>Type</u>	<u>Factory</u>	<u>Description</u>
E	Trace-lite	TL118 PL 42 120/277PC*
F	Trace-lite	TL 117 MH 150 MT PC*
X1	Exitronix	400U LB*
X2	Exitronix	400U LB*
X3	Exitronix	400U LB*

End of Addendum # 4

PWCPS BID # S-BB-9607

PURCHASING DEPARTMENT