



# Prince William County

PUBLIC SCHOOLS

*Providing A World-Class Education*

## ADDENDUM

ADDENDUM # 02

DATE: October 14, 2009

**REFERENCE:** Invitation for Bid: **S-LB-10601**  
IFB Issue Date: **September 24, 2009**  
Title & Location: Brentsville Transportation Center Storage Building  
Architect/Engineer: Moseley Architects  
Sealed Bid Due  
Date and Time: **October 20, 2009, 3:00 PM Local Prevailing Time**

**THE FOLLOWING CHANGES, ADDITIONS, DELETIONS AND CLARIFICATIONS ARE HEREBY MADE PART OF THE BIDDING REQUIREMENTS AND CONTRACT DOCUMENTS FOR THE ABOVE REFERENCED PROJECT AND SHALL BE TAKEN INTO ACCOUNT IN THE PREPARATION OF ALL BIDS AND THE EXECUTION OF ALL WORK. BIDDERS SHALL ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE APPROPRIATE SPACE ON THE BID FORM.**

### SPECIFICATIONS

#### SECTION 13125

Refer to Addendum No. 1, dated October 9, 2009, that added five metal building manufacturers under paragraph 2.1 A. Add the following note:

“All Metal Building Manufacturers listed under paragraph 2.1 A must meet the requirements of the specifications”.

#### SECTION 02200

Add the following note:

“Any and all topsoil intermixed or over laid with stone and gravel WITHIN the building footprint must be removed in accordance with specifications for Third Party inspection and certification of the building. This material may be used onsite as non-structural fill at the direction of the owner”.

### DRAWINGS

#### Drawing A4.1 – Building Elevations and Building Sections

Refer to Addendum No. 1, dated October 9, 2009, that added the following note to all Building Sections and Building Elevations: “Paint all exposed steel surfaces that are not prefinished”.

Delete this note and add the following: “Paint all exposed exterior steel surfaces that are not prefinished”.

**END OF ADDENDUM NO.2**

CENTRAL PURCHASING OFFICE