



Prince William County

PUBLIC SCHOOLS

Providing A World-Class Education

ADDENDUM

ADDENDUM # 01

DATE: November 18, 2008

REFERENCE: Invitation for Bid: **S-LB-9603**
IFB Issue Date: **November 6, 2008**
Title & Location: Eleventh High School
Architect/Engineer: Moseley Architects
Sealed Bid Due Date and Time: **December 4, 2008, 7:00 PM** Local Prevailing Time

THE FOLLOWING CHANGES, ADDITIONS, DELETIONS AND CLARIFICATIONS ARE HEREBY MADE PART OF THE BIDDING REQUIREMENTS AND CONTRACT DOCUMENTS FOR THE ABOVE REFERENCED PROJECT AND SHALL BE TAKEN INTO ACCOUNT IN THE PREPARATION OF ALL BIDS AND THE EXECUTION OF ALL WORK. BIDDERS SHALL ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE APPROPRIATE SPACE ON THE BID FORM.

SPECIFICATIONS

Table of Contents

Page TOC-3 item "08710 PWCPHS HS Finish Hardware (to be issued)" delete "08710 PWCPHS HS Finish Hardware (to be issued)" and substitute "08710 PWCPHS ES Finish Hardware."

Section 01010 PWCPHS-Summary of Work and General Provisions

Page 01010/2, in paragraph 1.2.E Allowances Item 1 at "An Allowance of three hundred thousand Dollars (\$745,000.00) has been..." delete at "An Allowance of three hundred thousand Dollars (\$745,000.00) has been..." and substitute at "An Allowance of seven hundred forty-five thousand Dollars (\$745,000.00) has been..."

Page 01010/3, in paragraph 1.2.E Allowances Item 6 at "An Allowance of two hundred thousand Dollars (\$225,000.00) has been..." delete at "An Allowance of two hundred thousand Dollars (\$225,000.00) has been..." and substitute at "An Allowance of two hundred twenty-five thousand Dollars (\$225,000.00) has been..."

Section 08710 PWCPHS ES-Finish Hardware

Insert entire specification section attached (pages 08710/1-08710/73.)

Section 15083 Pipe Insulation

Page 15083-16, in paragraph 3.16 Interior Insulation Application Schedule at "Item I. Items 1-6" delete "Item I. Items 1-6" entirely.

CENTRAL PURCHASING OFFICE

Page 15083-16, in paragraph 3.16 Interior Insulation Application Schedule at Item J. at "Items 1-6" delete "Items 1-6" and substitute "Refer to Fixture Section 15410."

Page 15083-16 paragraph 3.17 Exterior Insulation Application Schedule Item C at "Items 1-6" delete "Items 1-6" entirely.

Page 15083-17 paragraph 3.17 Exterior Insulation Application Schedule at "Item D" delete "Item D" entirely.

Following Section 15194 Gas Fuel Piping (at end of Volume 2)

Delete entire "Memo dated October 16, 2008." *Clarification: This two page Memo was accidentally placed in the specification and is not intended to be part of this project.*

Section 15815 Metal Ducts

Page 15815-3 and 15815-4, in paragraph "2.3 Duct Liner Item A and B" delete entire paragraph "2.3 Duct Liner Item A and B."

Section 15820 Duct Accessories

Page 15820-9, in paragraph 2.11.B.3 at "Thermal Characteristics: R-8.0" delete "Thermal Characteristics: R-8.0" and substitute "Thermal Characteristics: R-4.0."

DRAWINGS

Drawing A3.3

Refer to "Door and Frame Schedule"

Door A001E in the "HDWR" column at "1Q" delete "1Q" and substitute "7B."

Door C033 in the "HDWR" column at "101E.1" delete "101E.1" and substitute "101E.2."

Door D026 in the "HDWR" column at "1R" delete "1R" and substitute "7A."

END OF ADDENDUM #1