



ADDENDUM

ADDENDUM # 1

DATE: June 4, 2009

REFERENCE: Invitation for Bid: S-LB-9609
IFB Issue Date: May 28, 2009
Title & Location: CD Hylton high School Vestibule and Potomac High School Fire Doors
Architect/Engineer: Moseley Architects
Sealed Bid Due Date: June 11, 2009, 2:00 p.m., Local Prevailing Time

THE FOLLOWING CHANGES, ADDITIONS, DELETIONS AND CLARIFICATIONS ARE HEREBY MADE PART OF THE BIDDING REQUIREMENTS AND CONTRACT DOCUMENTS FOR THE ABOVE REFERENCED PROJECT AND SHALL BE TAKEN INTO ACCOUNT IN THE PREPARATION OF ALL BIDS AND THE EXECUTION OF ALL WORK. BIDDERS SHALL ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE APPROPRIATE SPACE ON THE BID FORM.

DRAWINGS

POTOMAC HIGH SCHOOL FIRE DOORS

DRAWING A1

Revised Jamb Detail; Refer to attached addendum drawing ADD1-A1.

Revised Partial Section; Refer to attached addendum drawing ADD1-A2.

Revised Demolition Plan; Refer to attached addendum drawing ADD1-A3.

Revised Floor Plan, added magnetic hold open device locations; Refer to attached addendum drawing ADD1-A4.

Added magnetic hold open device note; Refer to attached addendum drawing ADD1-A5.

CD HYLTON HIGH SCHOOL VESTIBULE

DRAWING A2.1

Room Finish Schedule: Add note "At space 102, install VCT at new slab only. Existing terrazzo shall remain exposed. Provide transition strip at intersection of new VCT and existing terrazzo."

Reflected Ceiling Plan: Add note "Provide new ceiling grid where required in order to provide support for ceiling tiles adjacent to new gyp board bulkhead."

DRAWING A2.2

Detail 4/A2.2: Delete note "Locate angle at +4'-0" & +8'-6" " and substitute "Locate angle at +8'-6" "

Detail 6/A2.2: Add note "Brace top of HSS column to existing steel framing above, in perpendicular directions, with L4x4x1/4 braces. Set angle of brace to an approximate 45 degree angle. Locate braces to avoid existing conduit. "

DRAWING M2.1

Graphic Legend; Refer to attached addendum drawing ADD1-M1.

DRAWING M2.1

General Notes; Refer to attached addendum drawing ADD1-M2.

Drawing E1

Keynote 7: Delete "...at nearest telecommunication room" and substitute "...in telecommunications room as indicated on drawing E1 Partial Floor Plan-Electrical"

SPECIFICATIONS

SECTION 05500 – METAL FABRICATIONS

Issue herewith new section attached to this addendum.

SECTION 08411 – ALUMINUM ENTRANCES AND STROEFRONT

Issue herewith new section attached to this addendum.

SECTION 09910 – PAINTS

Issue herewith new section attached to this addendum.

END OF ADDENDUM #1